



OFFICE OF P.H. SUB-DIVISION, CHARBATIA

Ph. #0671-2394500, E-Mail - aeecharbatiact@gmail.com

No. 349 // Date. 13.07.23
W.F

To

The Principal,
The BIPF School,
Banipada, Choudwar

Sub: - Issue of water & Sanitation Certificate.


Sir,


With reference to the subject cited above, I am to intimate you that, as per water sample test report of Joint Director cum Chief Food Analyst, Bhubaneswar vide their letter no. 1500/JDCFA dt. 11.07.2023, the water sample is tested and found potable for drinking water purpose. During my visit to your invitation on dt. 13.07.2023 the sanitation system made by the school is found satisfactory.

This is for favour of your kind information and necessary action.

Encl: As above – Water & Sanitation Certificate – 1 no.

Yours faithfully,


13.7.23
Assistant Executive Engineer
P.H. Sub-Division, Charbatia


PRINCIPAL
THE BIPF SCHOOL
Banipada, Choudwar
Affiliation No-1530394
School No-16175


CHAIRMAN
THE BIPF SCHOOL
Banipada, Choudwar

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 349

Dated: 13.7.2023

It is certified that an inspection team headed by Sambhram Sethy
(Name of Officers with designation) from Assistant Executive Engineer
(Name of Department/ Office) inspected the P.H. Sub-Division, Charabata
(Name & Address of the school) on 13.7.2023.....(date of inspection), checked the water test report
submitted by the school and found that the school has potable drinking water for students and staff of the
institution and is having provision for running water in the toilets and maintaining hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year.

Signature with Seal:

Assistant Engineer
P.H. Sub-Division, Charabata

Name

: Sambhram Sethy

Designation

: Assistant Executive Engineer
P.H.

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department : H.A.U.D

To

Principal
The B.I.P.F. School
Banipada, Choudwa

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

GOVERNMENT OF ODISHA
OFFICE OF THE JOINT DIRECTOR CUM CHIEF FOOD ANALYST
State Food Testing Laboratory, Convent Square, Bhubaneswar-1

No. 1500 /JDCFA Dated Bhubaneswar the 11 th 07 '2023'

To,

The BIPF School
Banipada, Choudwar, Cuttack.

Sub: -Analysis report of water Sample.

Report No.	Source: -	*Collected/*Sent by	Reference No.& Date of Collection/Receipt	Date of Examination
825/23	Borewell Water	R.K.Behera	04.07.23	04.07.23

Chemical and Bacteriological Examination of water samples

The sample of water from above source has been caused to be analysed as per the specification of Indian Standard of drinking water under IS: 10500:2012 and the findings are as under:

<i>Physical Examination</i>				<i>Chemical Examination</i>			
Sl. No.	Test/Characteristic	Result	Permissible Limit as per IS:10500:2012	Sl. No.	Test/Characteristic	Result mg./ltr (ppm)	Permissible Limit as per IS:10500:2012
1	Colour	Nil	Agreeable	1	Total hardness as CaCO ₃ (mg/l)	42	200 mg/l Max
2	Odour	Nil	Agreeable	2	Iron (as Fe) (mg/l)	Nil	1.0 mg/l Max
3	Turbidity	Nil	1 NTU max.	3	Chloride (as Cl ⁻) (mg/l)	32	250 mg/l Max.
4	pH	6.7	6.0 to 8.5	4	Residual free Chlorine (mg/l)	Nil	0.2 mg/l Max.
<i>Bacteriological Examination</i>				5	Sulphate as SO ₄ ⁻ (mg/l)	Nil	200 mg/l Max.
Sl. No.	Test/Characteristic	Result	Permissible Limit as per IS:10500:2012	6	Total Alkalinity (as HCO ₃ ⁻) (mg/l)	54	200 mg/l Max.
1	MPN of coli form group of organisms Per 100 ml	Absent (0)	Absent (0)	7	Nitrate (as NO ₃ ⁻)	Nil	45 mg/l Max.
2.	Test for E. coli.	Negative	Negative	8	Total Dissolved Solid (mg/l)	74.23	500 mg/l Max.
				9	Nitrite (as NO ₂ ⁻)	Nil	0.02mg/l Max.

Remarks: - The water sample is potable on the basis of test performed.

[Signature]
11/7/23

Dated:
State Food Testing Laboratory
Bhubaneswar-1

Food Analyst
GOVT. OF ODISHA

Food Analyst
Govt. of Odisha